

**Mandatory Public Notification Language
Notice of Drinking Water Treatment Technique Violation(s)**

CITY OF GORMAN TX0670003 has violated the treatment technique requirements set by Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems are required to properly disinfect water before distribution, maintain acceptable disinfection residuals within the distribution system, monitor the disinfectant residual at various locations throughout the distribution system, and report the results of that monitoring to the TCEQ on a quarterly basis.

Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites which can cause symptoms such as nausea, cramps, diarrhea, and associated headaches. During NOVEMBER AND DECEMBER, 2023, sufficient levels of chlorine residual were not met in more than five percent (5%) of monthly samples.

The following actions are being taken to address this issue:

Daily residuals are monitored very closely to ensure that they do not fall below the minimum.

<corrective actions>

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact Joe Williams at 254-734-2317.
<area code + phone number> <water system official's name>

Posted/Delivered on: 4/11/2024
<Date posted>